

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 2110059

Ordering firm: NOARK Electric Europe s.r.o.  
Sezemická 2757/2, 118 00 Praha 20, Horní Počernice, Czech Republic

Manufacturer/Licence holder: NOARK Electric Europe s.r.o.  
Sezemická 2757/2, 118 00 Praha 20, Horní Počernice, Czech Republic

Name of product: Contactor

Trade name:

Type of product: Ex9C  
variants: Ex9CS (06, 09, 12),  
Ex9C (09, 12, 18, 25, 32, 38, 40, 50, 65, 80, 100)

Rating: 3 and 4 pole, panel and DIN rail mounting , AC-3

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESC Mark” certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 103210-01/01 of: 27.10.2011

A sample of the product was tested and found to be in conformity with:  
ČSN EN 60947-4-1 ed.2:02+A1:03+A2:06

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. 102915-01 of 6.7.2011
- the Agreement on the use of the ESC Mark No. 103210 concluded between the ordering firm and the Electrotechnical Testing Institute

4.11.2011

Prague

Miroslav Sedláček  
Head of Certification Body



Stamp



\* C E R / 2 1 1 0 0 5 9 \*

103210-01